



Proposed Code Change  
State Form 41186R

RETURN TO:  
INDIANA DEPARTMENT OF HOMELAND SECURITY  
CODE SERVICES SECTION  
302 W. Washington Street Room W246  
Indianapolis, IN 46204

FOR OFFICE USE ONLY

Received 12/29/09

Code 115.5-09

INSTRUCTIONS:

Only TYPED copy accepted.

(KEY – ~~Dashed line through material to be deleted~~, underline material to be added)

Use second sheet for any material requiring more space.

Code Title 2009 Indiana Residential Code		Edition First Edition
Section number and title AE605.1 General		Page 1 of 1
Proponent James K. Keller	Title M H Director – Ind. Manufactured Housing Association	
Address 3210 Rand Road, Indianapolis, Indiana 46241		Phone 317-247-6258, Ext. 12
PROPOSED CODE CHANGE (Check One)		
<input checked="" type="checkbox"/> Change to read as follows <input type="checkbox"/> Add to read as follows <input type="checkbox"/> Delete and substitute as follows <input type="checkbox"/> Delete without substitution		
Change the first sentence of Section AE605.1 to read as follows:  Steel strapping or other approved materials shall be used for ties.		
REASON AND FISCAL IMPACT		
REASON: The use of cable or chain to anchor a home should only be under the direct supervision of a licensed design professional. These type products are not readily available for this use by an installer.		
FISCAL IMPACT: None. These type products are not readily available and therefore not in use at this time in any appreciable number.		
REVIEW RECOMMENDATION		
Approve		
Disapprove		
Approve as amended		
Further Study		